



Gwich'in Land and Water Board

Box 2018 Inuvik NT X0E 0T0

PH 867 777 7960 FX 867 777 7970

May 07, 2015

G 15 H 001

**Robert Charlie
Director – Gwich'in Services
Gwich'in Tribal Council
Box 1509
Inuvik NT X0E 0T0**

**Re: Issuance of a Type "A" Land Use Permit – G 15 H 001
Gwich'in Tribal Council
Gwich'in Camp on East Branch of the Mackenzie River
Camp and Fuel Storage**

Attached is Land Use Permit G 15 H 001, which has been approved and issued by the Gwich'in Land and Water Board (the Board) to the Gwich'in Tribal Council in accordance with the Mackenzie Valley Resource Management Act for the period commencing May 07, 2015, and ending on May 06, 2020.

Be advised that a copy of this letter, along with the Land Use Permit, all inspection reports and correspondence related thereto, will be filed in the Public Registry at the offices of the Gwich'in Land and Water Board in Inuvik, NT, as per the Mackenzie Valley Resource Management Act. This is intended to keep all interested parties informed of the manner in which the Land Use Permit requirements are being met. All Public Registry material will be considered if an amendment to the Land Use Permit is requested.

It is imperative that all persons working under the authority of this Land Use Permit are aware of and will adhere to the conditions as stated in permit.

I would like to point out a couple of recommendations made by reviewers:

- The Land Use Inspector recommended that a more stable platform/base be provided for the storage to sit on, as the current one is unstable (See attached photo).
- Environment Canada recommends that the Proponent review the E2 Regulations in detail to determine whether any substances being stored on site meet the reporting requirements of the regulation.
- All storage tank system owners must identify their tank systems to EC and display the EC identification number on or near the tank system according to the Storage Tank Systems for Petroleum Products and Allied Petroleum Products Regulations.

The GLWB recommended that the fuel storage be monitored monthly for leaks by both visual monitoring as well as dipping the tank to determine actual volume of fuel present at the time of inspection and keeping a written record of these inspections and fuel volumes. The GLWB or the Land Use Inspector may request a copy of these inspections at any time.

If you have any questions, do not hesitate to contact Bonnie Bergsma at (867) 598-2413 ext 227 or email bonnie.bergsma@slwb.com.

Paul Sullivan

Paul Sullivan
Chair, Gwich'in Land and Water Board

Copied to: Conrad Baetz, North Mackenzie District, Department of Lands, Inuvik

