

Elaine Briere - MVLWB

From: Shannon Hayden - MVLWB [shayden@mvlwb.com]
Sent: Wednesday, January 13, 2010 8:46 AM
To: permits@mvlwb.com; 'Wilson, Anne [Yel]'; 'Patrick Clancy'; catherine.mallet@inac-ainc.gc.ca; wayne.starling@inac-ainc.gc.ca; todd_paget@gov.nt.ca; mary.kelly@EC.GC.CA; gerald_enns@gov.nt.ca; diep_duong@gov.nt.ca; donihee@telusplanet.net; 'Joe Murdock'; 'Jamie VanGulck'
Cc: Marty.Sanderson@inac.gc.ca; Charlene.Coe@inac-ainc.gc.ca; norrisa@inac.gc.ca; Robert.Jenkins@inac.gc.ca; consultationsupportunit@inac.gc.ca; james.lawrance@inac.gc.ca; intergov@inac-ainc.gc.ca; sealel@inac-ainc.gc.ca
Subject: FW: MV2009L30005 Response to INAC Intervention
Attachments: MV2009L30005 Jan 12 2010 Response to INAC Intervention Recommendations Final.pdf

Good morning,
The Town of Hay River's Response to INAC's Intervention is attached.
Thanks,
Shannon

From: Michael Richardson [mailto:mrichardson@hayriver.com]
Sent: Tuesday, January 12, 2010 6:45 PM
To: 'Shannon Hayden - MVLWB'
Cc: Terry Molenkamp; 'Ron Kent'
Subject: MV2009L30005 Response to INAC Intervention

Shannon,

I have attached our response to INAC's intervention recommendations of Dec 2/09.

<<...>>

Please forward as appropriate.

Thank you,

Michael Richardson
Director of Public Works & Planning
Town of Hay River

73 Woodland Dr.
Hay River, NT X0E 1G1
T: 867-874-6522 x 217 C: 867-875-7365
mrichardson@hayriver.com



Town of Hay River
73 Woodland Drive
Hay River, NT X0E 1G1
Phone: 867-874-6522
Fax: 867-874-3237
email: mrichardson@hayriver.com
townhall@hayriver.com

January 12, 2010

Shannon Hayden
Regulatory Officer
Mackenzie Valley Land and Water Board
PO Box 2130
Yellowknife, NT X1A 2P6

Sent by email: shayden@mvlwb.com

Re: Water License Application MV2009L3-0005
Responses to Indian & Northern Affairs Canada Intervention

Dear Ms. Hayden:

The Town of Hay River would like to submit its response to the recommendations contained in the Indian and Northern Affairs Canada Intervention of December 2nd, 2009 regarding Water License Application MV2009L3-0005:

#	INAC Recommendation	Town of Hay River Response
1	Scope and definition of sewage disposal facilities	Agreed
2	Reflect new sewage lagoon in Part D.	Agreed
3	Notify Inspector prior to removal of one treatment cell; request permission to remove more than one.	Agreed
4	Review Snow Disposal Plan annually	Agreed
5	Refer to INAC's April 2007 Guidelines for Spill Contingency Planning	Agreed



6	Review O&M Plan annually and have revisions approved by the Board	Agreed
7	Add CBOD for three years then submit a trend analysis.	Agreed
8	Decrease bioassay sampling frequency to twice annually.	Disagree. The Town maintains its position that bioassay sampling should not be required for the reasons previously provided, but will assist the Government at no cost to us by collecting the samples on their behalf.
9	Submit groundwater monitoring analysis with annual report	Agreed
10	Update O&M plan to include Hydrocarbon Biopile Treatment.	Agreed. We have now retained a consultant to prepare a plan.
11	Report sample results for leachate from the Hydrocarbon Biopile Treatment.	Agreed
12	Submit a Closure & Reclamation Plan for the MSW site for approval.	Agreed. As you know, the Town is currently studying the MSW site. The consultant will provide an O&M plan that is incorporates "close as you go". This plan will be submitted as part of a preliminary Closure & Reclamation plan. The study will be available by the end of March 2010. A final C&R plan will be submitted in the future.

If you have any questions, please contact me at mrichardson@hayriver.com or 867-874-6522.

Sincerely,

Michael Richardson
Director of Public Works and Planning