

Elaine Briere - MVLWB

From: Lynn Carter - MVLWB [lcarter@mvlwb.com]
Sent: Wednesday, February 17, 2010 2:32 PM
To: walexander@yellowknife.ca; lmandeville@denenation.com; screeningofficer@eastarm.com; lands@nsma.net; eddieerasmus@tlicho.com; rae_edzometisnation@theedge.ca; environment@ykdene.com; tslack@ykdene.com; sonyaalmond@hotmail.com; Scott.Stewart@inac.gc.ca; 'Charlene Coe'; catherine.Mallet@inac-ainc.gc.ca; norrisa@inac.gc.ca; consultationsupportunit@inac.gc.ca; james.lawrence@inac.gc.ca; sealel@inac-ainc.gc.ca; Intergov@inac-ainc.gc.ca; ec.ea.nwt@ec.gc.ca; Anne.wilson@ec.gc.ca; Jane.Fitzgerald@ec.gc.ca; Rick.Walbourne@dfo-mpo.gc.ca; sophia.garrick@tc.gc.ca; christopher.aguirre@tc.gc.ca; Robert_Jenkins@inac.gc.ca; Glen_Mackay@gov.nt.ca; Patrick_Clancy@gov.nt.ca; Gnwt_ea@gov.nt.ca; Duane_fleming@gov.nt.ca; Mark_Davy@gov.nt.ca; Dave_Jones@gov.nt.ca; SusanA@wcb.nt.ca; K_Johnson@gov.nt.ca; Rhonda_Batchelor@gov.nt.ca; vchristensen@mveirb.nt.ca
Cc: 'Anne Umpleby'; 'Zabey Nevitt - MVLWB'; 'Jennifer Bayly-Atkin'; permits@mvlwb.com
Subject: re: MV2009L3-0007 - City of Yellowknife Draft WL Matters

Hello All –

The draft WL for the City of Yellowknife was sent out last week. Again, comments are due by **5 pm on March 4, 2010**.

Upon review of the draft that was sent to you last week there are a couple of issues I wanted to point out to let you know that we are aware of them. These are:

- text alignment problems throughout the document;
- numbering\lettering formatting inconsistencies; and
- numbering issues (in particular under Part D, and Part F)

As well, I would like to bring your attention to Part D item 2. This condition should read as below (on your version the Faecal Coliform line is missing):

All sewage effluent discharged from the Sewage Disposal Facilities at Surveillance Network Program Station Number 0032-F3 shall meet the following effluent quality standards:

<u>Parameter</u>	<u>Maximum Average Concentration</u>	<u>Maximum Grab Sample</u>
Faecal Coliform	200 FC per 100 ml	400 FC per 100 ml
BOD ₅	20 mg/L	30 mg/L
Total Suspended Solids	20 mg/L	40 mg/L
Oil and Grease	No visible sheen	

Toxicity Acute-Rainbow Trout: 70% survival of all organisms

Toxicity Acute-Daphnia magna: 70% survival of all organisms

The waste discharged shall have a pH between 6 and 9

Please accept our apologies for these errors and any confusion it may have created. Note that the matters mentioned above will be fixed in the final version of this WL. Again, if you have any questions or concerns, do not hesitate to contact me.

Thanks and have a good week!

Lynn

Lynn Carter

Regulatory Officer

Mackenzie Valley Land and Water Board

4910 50th Avenue

P.O. Box 2130

Yellowknife, NT X1A 2P6

Ph: (867)669-0506

Fax: (867)873-6610

email: lcarter@mvlwb.com