



South Mackenzie
#41 Capitol Drive #203
Hay River , NT X0E 1G2

Telephone: (867) 874-6995
Fax: (867) 874-2460

June 13, 2013

Alan Harris
Manager Municipal Works
Hamlet of Fort Liard
General Delivery
Fort Liard, NT X0G 0A0

Via email

Dear Mr. Harris:

Re: Sewage Effluent Decant – Water License MV2009L3-0025.

The undersigned Inspector acknowledges receipt of your request dated June 11, 2013 regarding the Hamlet of Fort Liard's request for permission to conduct a decant of the sewage lagoon cell 3 and the old lagoon cell.

With regards to this request, decanting can go ahead once the sample results are received and they meet the license parameters as per Part D, Item 2 of the above mentioned Water License. These results to be provided to both inspector and the Land and Water Board.

In future, decants should be occurring before the freeboard levels are exceeded to ensure compliance with the water license

Thank you for your correspondence and I look forward to receiving the results of the effluent samples.

Sincerely,

Original Signed

Rob Walker
Field Operations Supervisor
Aboriginal Affairs and Northern Development Canada
rob.walker@aandc.gc.ca
(867) 874-6995

Copied to: Scott Stewart, South Mackenzie District Manager, AANDC
Laurie Ozmun, RMO- Ft Simpson , AANDC
Municipal & Community Affairs, GNWT
Jenn Potten , MVLWB

Canada 

