

From: Sonja Martin-Elson
To: [Erica James](#)
Subject: FW: Fort Liard Decant
Date: Tuesday, July 3, 2018 8:50:05 AM
Attachments: [image001.png](#)

Hi Erica,

I was out of town but I made sure that Alan knew to contact Nahum about it and he approved them. I've attached his approval.

If you have any more question feel free to let me know.

Márisi | Kínaskomitin | Thank you | Merci | Hg' | Quana | Qujannamiik | Quyanainni | Máhsu | Máhsu | Mahsi

Sonja Martin-Elson
Water Resource Officer
Dehcho
Environment and Natural Resources
Government of the Northwest Territories

PO Box 240
9910-105 Avenue
Fort Simpson, NT X0E 0N0

Phone: 867-695-7477
Fax: 867-695-2381
www.gov.nt.ca

This message is intended only for the use of the individual or entity to which it is addressed and may contain information that is privileged, confidential and exempt from disclosure under applicable law. If the reader of this message is not the intended recipient, or the employee or agent responsible for delivering the message to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you have received this communication in error, please delete it immediately and notify us by telephone. Thank you.

From: Nahum Lee
Sent: Thursday, June 28, 2018 11:35 AM
To: mws@fortliard.com
Cc: Sonja Martin-Elson; Carl Lafferty
Subject: Fort Liard Decant

Hello AI,

Thank you for forwarding the results from Cells 2 and 3 SNP sampling. The undersigned inspector hereby authorizes the decant of these cells in order to preserve infrastructure and for the general operation and maintenance activities to proceed. Please note the sampling requirements during decant as outlined in the SNP of your water licence, attached.

2. Sampling and Analysis Requirements

- a) Water at station number 1478-6 and 1478-9 shall be sampled one week prior to discharge and weekly during discharge. If the decant period is less than seven days, station numbers 1478-6 and 1478-9 shall be sampled on the first and last day of decant. Station numbers 1478-6 and 1478-9 shall be analysed for the following parameters:

pH	Ammonia-Nitrogen
Faecal Coliform	BOD ₅
Total Suspended Solids	Total Dissolved Solids
Conductivity	CBOD

Also of note, the sample results provided did not contain BOD results. Please ensure that this parameter is included in your request to the lab during future sampling events. The TSS levels were also slightly elevated in both Cell 2 and 3. I will be interested to see the TSS results from Station 1478-6 during the decant process. Take care and have a good day.

Regards,

Nahum