



Sahtu Land and Water Board

P.O Box 1
Fort Good Hope, NT
X0E 0H0
Phone: 867-598-2413
Fax: 867-598-2325
www.slwb.com

October 6, 2016

S13L1-007

Lindsay Hollands
Environment and Regulatory Advisor
Norman Wells Operations
Bag 5000
Norman Wells NT
X0E 0V0

Re: Water Licence S13L1-007 – Interpretation of Annex A, Part C:4

Dear Lindsay,

The Board met on September 7, 2016 and discussed the July 28, 2016 letter submission from Imperial Oil Resources regarding the interpretation of the water licence condition in Annex A, Part C, Item 4 : A daily grab sample of water at SNP Station S13L1-007 – 2 shall be field analyzed for Total Residual Chlorine.

The Board agreed with the interpretation provided: This condition applies only when the chlorine injection system is operational. In circumstances where the chlorine injection is out of service and no chlorine is being injected into the freshwater cooling process, no analysis will occur.

There were no further questions or concerns with the above licence interpretation.

Sincerely,

Bonnie Bergsma, M.Sc.
Regulatory Specialist
Sahtu Land and Water Board

cc: Tim Morton, INAC, Yellowknife