



August 27th 2019

File: W2012L2-0001

Dustin Chaffee
Environment Advisor – Permitting
Dominion Diamond Mines ULC
900-606 4 Street Calgary Alberta SW
Calgary, Alberta T2P 1T1

RE: W2018C0005 Request to Store Fuel Within 100m of Watercourses

Dear Mr. Chaffee.

Please accept this letter as written authorization under Condition 46. Of Land Use Permit W2018C0005 to place Fuel Storage Containers or Tanks within 100 meters of the Ordinary High Water Mark of the water sources used for exploration drilling. This authorization is subject to the following conditions:

- Fuel Storage Containers or Tanks shall be placed on a stable level platform or level ground
- Fuel Storage Containers or Tanks shall not be placed within 30 meters of the Ordinary High Water Mark of any Watercourse
- Fuel Storage Containers or Tanks will be double walled and placed within a containment tray
- Fuel containers or tanks shall be inspected at a minimum of once per 12 hour shift to ensure there are no leaks or spills
- A spill kit will be placed near the fuel tank to help facilitate spill response if necessary

This authorization is in effect for the remainder of the Summer 2019 Exploration Program only; Dominion will need to seek a separate approval for future drilling programs. Thank you for your cooperation.

Sincerely,

Jamie Steele
Manager Diamond Resource Management

GNWT – Department of Lands

Cc: Lynn Boettger – Superintendent-Permitting, Dominion Diamond Mines ULC
Scott Stewart – Regional Superintendent, GNWT Department of Lands
Meghan Schnurr – Regulatory Specialist, Wek'eezhii Land and Water Board
Anneli Jokela – Regulatory Manager, Wek'eezhii Land and Water Board
Marc Casas – Executive Director, Independent Environmental Monitoring Agency