

NT-NU SPILL REPORT

OIL, GASOLINE, CHEMICALS AND
OTHER HAZARDOUS MATERIALS



NT-NU 24-HOUR SPILL REPORT LINE

Tel: (867) 920-8130 • Fax: (867) 873-6924 • Email: spills@gov.nt.ca

REPORT LINE USE ONLY

A	Report Date: 05 09 21	Report Time: 12:20 pm	<input checked="" type="checkbox"/> Original Spill Report		Report Number:
	Occurrence Date: 05 09 21	Occurrence Time: 6:50 am	OR <input type="checkbox"/> Update # _____ to the Original Spill Report		
C	Land Use Permit Number (if applicable): MV2019X0007		Water Licence Number (if applicable): MV2007L8-0031		
D	Geographic Place Name or Distance and Direction from the Named Location: Giant Mine			Region: <input checked="" type="checkbox"/> NT <input type="checkbox"/> Nunavut <input type="checkbox"/> Adjacent Jurisdiction or Ocean	
E	Latitude: _____ Degrees _____ Minutes _____ Seconds		Longitude: _____ Degrees _____ Minutes _____ Seconds		
F	Responsible Party or Vessel Name: Parsons Inc.		Responsible Party Address or Office Location: Yellowknife		
G	Any Contractor Involved: Deton Cho Nuna Joint Venture		Contractor Address or Office Location: Yellowknife		
H	Product Spilled: <input type="checkbox"/> Potential Spill Wastewater (snowmelt contact water)	Quantity in Litres, Kilograms or Cubic Metres: approximately 15 cubic metres	U.N. Number:		
I	Spill Source: Sump across/east of the C-Dry Building	Spill Cause: inadequate equipment	Area of Contamination in Square Metres: approximately 250 square metres		
J	Factors Affecting Spill or Recovery: Weather	Describe Any Assistance Required:	Hazards to Persons, Property or Environment:		
K	Additional Information, Comments, Actions Proposed or Taken to Contain, Recover or Dispose of Spilled Product and Contaminated Materials: At approximately 7:00 am today, May 9, 2021, the site management reported approximately 15 cubic metres of sump water from across/east of the C-Dry Building overflowed to the access road, southerly towards the parking lot and into the ditch east of the access road. Refer to the attached drawing. Water in the ditch follows flow path #49 per the drawing as non-contact water with no connection to Baker Creek due to inactive culvert C16. The site management via its subcontractor SCMC has since stopped the overflow and initiated pumping water from the sump to the Mill Pond. SCMC is considering mobilizing a vacuum truck to transport the ditch water to the Northwest Pond.				
L	Reported to Spill Line by: Norlito Cezar	Position: Environmental Manager	Employer: Parsons Inc.	Location Calling From: Yellowknife	Telephone: (867) 669-3725
M	Any Alternate Contact: Doug Hayes	Position: Mine Manager	Employer: Parsons Inc.	Alternate Contact Location: Yellowknife	Alternate Telephone: (867) 669-3715

REPORT LINE USE ONLY

N	Received at Spill Line by:	Position:	Employer:	Location Called:	Report Line Number:
Lead Agency: <input type="checkbox"/> EC <input type="checkbox"/> CCG/TCMSS <input type="checkbox"/> GNWT <input type="checkbox"/> GN <input type="checkbox"/> ILA <input type="checkbox"/> AANDC <input type="checkbox"/> NEB <input type="checkbox"/> Other: _____		Significance: <input type="checkbox"/> Minor <input type="checkbox"/> Major <input type="checkbox"/> Unknown		File Status: <input type="checkbox"/> Open <input type="checkbox"/> Closed	
Agency:		Contact Name:	Contact Time:	Remarks:	
Lead Agency:					
First Support Agency:					
Second Support Agency:					
Third Support Agency:					




Figure 1. Sump water overflows into ditch water south of the C-Dry Building.