From: Shannon Allerston
To: Emma Junker
Subject: FW: Water License
Date: Friday, October 7, 2022 3:26:27 PM

From: Shannon Allerston
Sent: Friday, October 7, 2022 3:25 PM
To: dave drwgcl.com <dave@drwgcl.com>; Clint Ambrose <Clint_Ambrose@gov.nt.ca>; David-Scott McQuinn <David-Scott_McQuinn@gov.nt.ca>; Brandon Bradbury <Brandon_Bradbury@gov.nt.ca>
Cc: Katherine Harris <kharris@mvlwb.com>
Subject: RE: Water License

HI Dave,
Board Staff have the following comments on this submission and expect the sampling results will be submitted once received.

Table 1:

- missing SNP 3b
- SNP 6 should have a and b
- SNP 9 was sampled but Licence has 9, 9a, 9b, and 9c so it is not clear if sampling occurred at one or more locations
- SNP 11 is supposed to be sampled daily for flow and volume when camp is in use. Table 3 includes a total volume used but there is no daily flow or volume included
- SNP 12a is missing – it is still open water so a sample should have been collected there

Item 2(d) - There is no information provided re: meters and the flow and volume for SNP 11. If a tank was just filled to a known volume or something along those lines, that should be clear (either explained under the meter section re: why no info is there or as a footnote to Table 1 and/or 3.

Table 2 title refers to WGS83 but WGS is WGS84 and NAD is NAD83?

Table 3 – The cumulative total for the year does not seem to make sense: 80 m3 listed for total in Jan but the cumulative total is 906.8. NDM should identify how its annual water use volume is being calculated.

Thanks
Shannon and Katherine

From: dave drwgcl.com <dave@drwgcl.com>
Sent: Thursday, October 6, 2022 11:57 AM
To: Shannon Allerston <sallerston@mvlwb.com>; Clint Ambrose <Clint_Ambrose@gov.nt.ca>; David-Scott McQuinn <David-Scott_McQuinn@gov.nt.ca>; Brandon Bradbury

<Brandon_Bradbury@gov.nt.ca>
Subject: Water License

Please find attached the Surveillance Network report for September.

Dave Webb