



- NOTES:**
- WELL CASING SHALL HAVE A BOTTOM PLATE, BOTTOM 1.8m [6'] OF CASING SHALL BE PERFORATED AT 150mm [6"] CENTRES
 - THE EXISTING SHORELINE SHALL REMAIN UNCHANGED FOLLOWING CONSTRUCTION
 - EXCAVATE INLET AS SHOWN, EXCAVATED MATERIAL TO SPOIL PILES
 - BACKFILL WITH CLEAN PIT RUN GRAVEL FROM PIT "W". STOCKPILE FILL NEAR SITE PRIOR TO EXCAVATION
 - NON-WOVEN GEO TEXTILE SHALL BE NILEX STYLE 4512 OR APPROVED EQUIVALENT
 - (2) DN200 [8"] PERFORATED PIPES SHALL EXTEND INTO FOREBAY AND BE CAPPED
 - INSTALL TEMPORARY SILT CURTAIN IN FOREBAY TO MITIGATE SPREAD OF SILT DURING CONSTRUCTION
 - LAKE ELEVATION 2020/09/05: 240.49m [789.02"], CREST ELEV. OF SOUTH VALLEY SPILLWAY: 239.33m [785.20"]
 - PUMP HOUSE CONSTRUCTION:
 - WALLS SHALL BE STICK FRAMED 2x6 AT 410mm [16"] O.C., INSULATED TO R20 C/W 9mm [3/8"] PLYWOOD SHEATHING, BUILDING WRAP AND WHITE EXTERIOR METAL SIDING. VAPOUR BARRIER ON INSIDE OF STRUCTURE COMPLETE WITH 9MM [3/8"] PLYWOOD SHEATHING AND ELECTRICAL
 - ROOF SHALL BE STICK FRAMED 2x6 AT 410mm [16"] O.C., INSULATED TO R20 C/W 3/4" PLYWOOD ROOF DECKING, ICE GUARD AND ROOFING PER CLIENT SPEC.
 - FLOOR FRAMING SHALL BE 2x10 AT 410mm [16"] O.C., COMPLETE WITH 19MM [3/4"] T&G PLYWOOD DECK, NO INSULATION.
 - ONE 915mm [36"] MAN DOOR ON SOUTH WALL OF STRUCTURE
 - FLOOR FRAMING SHALL BE 2x10 AT 410mm [16"] O.C., COMPLETE WITH 19MM [3/4"] T&G PLYWOOD DECK, NO INSULATION.
 - BUILDING SHALL BE COMPLETELY SKIRTED, FRAME SKIRTING WITH 2x6 LUMBER, SKIRTING PER CLIENT SPEC, INSULATED TO R20

										PROFESSIONAL STAMP	PERMIT STAMP	LOCATION TALSTON, NT	
										TITLE TALSTON CAMP WATER SUPPLY WELL AND PUMP HOUSE LOC'N SITE PLAN & SECTIONS			
										SCALE NTS	SHEET 1 OF 1	DRAWING NO. -	REV. 0

ID	DRAWING NO.	TITLE	REVISION LETTER	ORIGINAL	REVISION	WORK ORDER	NAME	DATE	CHECKED BY	DESIGNED BY	STATUS OF DRAWING	DATE
-	-	-	0	ISSUED FOR CONSTRUCTION	-	-	-	-	LC	LC	IFC	2021-03-09
-	-	-	A	ORIGINAL	-	-	SDM	2020-12-04	LC	LC	IFR	2020-12-04