

## Land Use Permit MV2024E0003 - GNWT-INF - Condition #62 - Maximum Fuel on Site

Clint Ambrose <Clint\_Ambrose@gov.nt.ca>

Thu 2024-06-06 11:21 AM

To: Tyree Mullaney <tyree@mvlwb.com>

Cc: Karine Gignac <Karine\_Gignac@gov.nt.ca>

Good morning Tyree,

Upon review of the above noted land use permit, Condition #62 appears to have the wrong volume included, it should be 100,000 Litres as requested by the Permittee on ORS. Would it be possible to call this an administrative error and have the permit updated, or will the Permittee have to apply for an amendment?

GNWT-Lands - North Slave Region: Clint Ambrose

 Response submitted after review period ^

		<p>otherwise authorized in writing by an Inspector. (Reclaim non-oil and gas sumps).</p>	
06.	<b>Topic</b>	Draft Land Use Permit - Condition #63 (Maximum Fuel on Site)	February 7, 2024
	<b>Comment</b>	The Permittee and Contractors will be limited to a maximum of 50,000 Litres of fuel on site at any one time. In previous operations, Contractors have used envirotanks (75,000 to 100,000 Litres) with a capacity greater than this volume.	
	<b>Recommendation</b>	The Applicant must propose a fuel volume that is greater than what is currently stated in Condition #63, otherwise land use operations could be hindered.	
	<b>Response(s)</b>	<p>Also, the Spill Contingency Plan will have to be updated with any new volumes proposed.</p> <p>The Maximum litres of fuel for the permit can be updated from 50,000L to 100,00L</p>	

Thanks Tyree.

Clint

Clint Ambrose  
Manager, Resource Management (Inspector)  
Land & Water North Slave Region  
Department of Environment and Climate Change  
Government of Northwest Territories

140 Bristol Avenue  
Yellowknife NT X1A 3T2

Phone.: 867-767-9188  
Cell.: 867-446-0769  
Fax: 867-873-9754

[www.gov.nt.ca](http://www.gov.nt.ca)