

Subject: Re: Modification Request

Date: Friday, May 8, 2020 at 9:19:19 AM Mountain Daylight Time

From: Morton, Tim (AADNC/AANDC)

To: Wickens, Christine A, Bonnie Bergsma

CC: Benz, Kara L, Crawford, Jody A, Pangracs, Steve J, Penney2, Devin (AADNC/AANDC)

Thanks Christine for the information and the call the other day. I'm fine with the proposed 24 hour timeline proposed as long as I'm kept up to date with the progress of the project.

As the discharge is not included in the Imperial water licence I will compare it to the baseline of the MacKenzie River, the CCME for aquatic organisms, and take into account the water licence sent to you from Bonnie. If no parameters of concern are noted then an approval to discharge will follow. If the water does contain high levels of a parameter then we will work together to deal with the situation.

My partner Devin Penney is back from his acting assignment. Please add him to all future emails, he is cc'd on this email.

Tim

Sent from my Bell Samsung device over Canada's largest network.

----- Original message -----

From: "Wickens, Christine A" <christine.a.wickens@exxonmobil.com>

Date: 2020-05-07 3:14 PM (GMT-07:00)

To: Bonnie Bergsma <bonnie.bergsma@slwb.com>, "Morton, Tim (AADNC/AANDC)" <tim.morton@canada.ca>

Cc: "Benz, Kara L" <kara.l.benz@esso.ca>, "Crawford, Jody A" <jody.a.crawford@esso.ca>, "Pangracs, Steve J" <steve.j.pangracs@esso.ca>

Subject: RE: Modification Request

Hi Bonnie & Tim,

I appreciate your feedback on Imperial's request to withdraw water to complete a tank hydrotest later this summer.

In follow-up to our discussions, I have updated and reattached the request (to include metals sampling and notification prior to discharge).

Tim – as mentioned, Bonnie had provided the [Transport Canada Licence S17L8-003 Water Licence](#) as an example of effluent quality criteria.

If you need any additional information to review this request, let me know.

Take care,

Christine Wickens, P.Eng.
Environment & Regulatory Advisor

Imperial
christine.a.wickens@exxonmobil.com P 587 476 5007
imperialoil.ca | [Twitter](#) | [YouTube](#)

From: Wickens, Christine A
Sent: Tuesday, April 28, 2020 11:15 AM
To: 'Bonnie Bergsma' <bonnie.bergsma@slwb.com>
Subject: RE: Modification Request

Hi Bonnie,

I appreciate you reaching out regarding the comments from Tim. I agree that it would be easiest for us to amend the request to reflect Tim's comments (for a full metals suite and 72 hour notification prior to discharge) prior to sending out for formal review.

I'll make these updates and send the updated request to you.

Take care,

Christine Wickens, P.Eng.
Environment & Regulatory Advisor
Imperial
christine.a.wickens@exxonmobil.com P 587 476 5007
imperialoil.ca | [Twitter](#) | [YouTube](#)

From: Bonnie Bergsma [<mailto:bonnie.bergsma@slwb.com>]
Sent: Tuesday, April 28, 2020 10:03 AM
To: Wickens, Christine A <christine.a.wickens@exxonmobil.com>
Subject: Modification Request

External Email - Think Before You Click

Good Morning Christine,

I have made the first step for processing the modification request by contacting Tim Morton to determine if the request would be acceptable to CIRNAC and if any additional information is required.

The response indicated a concern that the water could be contaminated with metals and recommended that in addition to the parameters and criteria listed within the request, that the water also be tested for a full sweep of total metals. The results of the tests must be submitted to the SLWB and the Inspector at least 72 hours prior to discharge to ensure the water is not considered a waste.

Would you like to amend the Modification request to include this additional testing requirement prior to our sending it out for formal review?

Thanks,
Bonnie

Bonnie Bergsma, M.Sc.
Regulatory Specialist
Sahtu Land and Water Board
P.O. Box 1

Fort Good Hope NT X0E 0H0
867-496-2778
Bonnie.bergsma@slwb.com

All correspondence to the Board, including emails, letters, faxes, and attachments are public documents and may be posted to the public registry.