



**Taiga Environmental Laboratory**  
4601-52nd Ave., Box 1320, Yellowknife, NT. X1A 2L9  
Tel: (867)-767-9235 Fax: (867)-920-8740

**Taiga Batch No.:**  
**200173**

**- FINAL REPORT -**

---

**Prepared For:** Community Government of Behchoko

**Address:** P.O. Box 68  
Behchoko, NT  
X0E 0Y0

**Attn:** Galvin Simpson

**Facsimile:** (867) 392-6967

---

**Final report has been reviewed and approved by:**

---

**Glen Hudy**  
**Quality Assurance Officer**

---

**NOTES:**

- Test methods and data are validated by the laboratory's Quality Assurance Program. Taiga Environmental Laboratory is accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) to ISO/IEC 17025 as a testing laboratory for specific tests registered with CALA.
- Routine methods are based on recognized procedures from sources such as
  - Standard Methods for the Examination of Water and Wastewater APHA AWWA WEF;
  - Environment Canada
  - USEPA
- Samples shall be kept for thirty (30) days after the final report is issued. All microbiological samples shall be disposed of immediately upon completion of analysis to minimize biohazardous risks to laboratory personnel. Please contact the laboratory if you have any special requirements.
- Final results are based on the specific tests at the time of analysis and do not represent the conditions during sampling.

**ReportDate:** Friday, May 01, 2020

**Print Date:** *Friday, May 01, 2020*

*Page 1 of 4*



## Taiga Environmental Laboratory

4601-52nd Ave., Box 1320, Yellowknife, NT. X1A 2L9

Tel: (867)-767-9235 Fax: (867)-920-8740

Taiga Batch No.:  
**200173**

### - CERTIFICATE OF ANALYSIS -

Client Sample ID: **SNP R3**

Taiga Sample ID: **001**

Client Project: W2014L3-0002

Sample Type: Sewage

Received Date: 24-Apr-20

Sampling Date: 24-Apr-20

Sampling Time: 10:00

Location: Rae SNP R3 and R4

Report Status: **Final**

Test Parameter	Result	Detection Limit	Units	Analysis Date	Analytical Method *	Qualifier
<b><u>Inorganics - Nutrients</u></b>						
Ammonia as Nitrogen	36.1	0.005	mg/L	28-Apr-20	SM4500-NH3:G	
Biochemical Oxygen Demand	79	2	mg/L	25-Apr-20	SM5210:B	
CBOD	74	2	mg/L	25-Apr-20	SM5210:B	
Chemical Oxygen Demand	179	10	mg/L	29-Apr-20	SM5220:D	
Phosphorous, Total	7.11	0.002	mg/L	28-Apr-20	SM4500-P:D	
<b><u>Inorganics - Physicals</u></b>						
pH	7.36		pH units	28-Apr-20	SM4500-H:B	
Solids, Total Suspended	6	3	mg/L	30-Apr-20	SM2540:D	
<b><u>Microbiology</u></b>						
Coliforms, Fecal	35200	100	CFU/100mL	24-Apr-20	SM9222:D	

Report Date: Friday, May 01, 2020

Print Date: **Friday, May 01, 2020**

Page 2 of 4



Taiga Environmental Laboratory  
4601-52nd Ave., Box 1320, Yellowknife, NT. X1A 2L9  
Tel: (867)-767-9235 Fax: (867)-920-8740

Taiga Batch No.:  
**200173**

**- CERTIFICATE OF ANALYSIS -**

Client Sample ID: **SNP R4**

Taiga Sample ID: **002**

Client Project: W2014L3-0002

Sample Type: Sewage

Received Date: 24-Apr-20

Sampling Date: 24-Apr-20

Sampling Time: 10:00

Location: Rae SNP R3 and R4

Report Status: **Final**

Test Parameter	Result	Detection Limit	Units	Analysis Date	Analytical Method *	Qualifier
<b><u>Inorganics - Nutrients</u></b>						
Ammonia as Nitrogen	17.9	0.005	mg/L	28-Apr-20	SM4500-NH3:G	
Biochemical Oxygen Demand	41	2	mg/L	25-Apr-20	SM5210:B	
CBOD	38	2	mg/L	25-Apr-20	SM5210:B	
Chemical Oxygen Demand	142	5	mg/L	29-Apr-20	SM5220:D	
Phosphorous, Total	4.83	0.002	mg/L	28-Apr-20	SM4500-P:D	
<b><u>Inorganics - Physicals</u></b>						
pH	7.15		pH units	28-Apr-20	SM4500-H:B	
Solids, Total Suspended	8	3	mg/L	30-Apr-20	SM2540:D	
<b><u>Microbiology</u></b>						
Coliforms, Fecal	10600	100	CFU/100mL	24-Apr-20	SM9222:D	

ReportDate: Friday, May 01, 2020

Print Date: *Friday, May 01, 2020*

*Page 3 of 4*



## Taiga Environmental Laboratory

4601-52nd Ave., Box 1320, Yellowknife, NT. X1A 2L9

Tel: (867)-767-9235 Fax: (867)-920-8740

Taiga Batch No.:

**200173**

### - CERTIFICATE OF ANALYSIS -

---

Client Sample ID: **SNP R4**

Taiga Sample ID: **002**

---

**\* Taiga analytical methods are based on the following standard analytical methods**

SM - Standard Methods for the Examination of Water and Wastewater

EPA - United States Environmental Protection Agency

ReportDate: Friday, May 01, 2020

Print Date: *Friday, May 01, 2020*

*Page 4 of 4*