

From: John Hazenberg [<mailto:sao@behchoko.ca>]
Sent: March 15, 2016 10:39 AM
To: Sarah Elsasser <selsasser@wlwb.ca>; 'Tyanna Steinwand' <Tyanna_Steinwand@gov.nt.ca>
Subject: FW: NWT Spill # 15-328

Hello Sarah and Tyanna,

I trust that the following email satisfies the requirement for unauthorized discharge reporting.

Mahsi Cho,

John Hazenberg

Senior Administrative Officer
Community Government of Behchoko
P.O. Box 68
Behchoko, NT X0E 0Y0
Email: sao@behchoko.ca
Phone: (867) 392-6500
Fax: (867) 392-6139
Cell: (867) 445-8837

From: Water Plant [<mailto:water@behchoko.ca>]
Sent: March 15, 2016 9:49 AM
To: 'John Hazenberg' <sao@behchoko.ca>
Subject: NWT Spill # 15-328

Hi john, hope this helps, I got info from Edzo Plant Log book.

August 5 2015

9:15 Foul smell downtown Edzo, upon arrival in the morning, came across sewer force main leak, corner of first access to Edzo. Shut down pumps at Sewer Lift Station, investigated found out that floats had failed, toppling and tripping floats switches, on and off causing water hammering in force main. Bruce had ordered to replace floats with milltronics and levelometer installed and working properly by DT. Called Ace Enterprise

August 6 2015

8:20 Ace Enterprise and Pick's Steam at leak site, leak had been tighten up for temporarily fix, Pick's Steam rest of the way of the forcemain to lagoon, Pressured system, no indication of a leak. 16:30 Called Doug Carr

August 7 2015

10:30 Spread hydrated lime on affected area and surroundings. Called Doug Carr

August 10 2015

Nahum Lee EHO inspected spill site, and valve leaking again, ordered to shut down lift station and use sewer truck to haul from Edzo Lift Station. Ace Enterprise concluded best to replace whole forcemain, as its asbestos cemet pipe. Ace replaced gasket to keep from leaking.

Pressured test system, no leak. Start up Lift station.

These notes are from Edzo Plant Log.

Galvin Simpson

Water Plant Operator
Community Government of Behchoko
Box 68
Behchoko,NT
X0E 0Y0
I(867)-392-6966
I(867)-392-6967(f)