

From: [Nahum Lee](#)
To: [Alex Packman](#)
Cc: [Anneli Jokela](#); [Roberta Judas](#); [Meaghan MacIntyre-Newell](#)
Subject: RE: Behchoko Landfill
Date: June 26, 2024 10:15:03 AM

Hello Alex,

Thank you for the notification and request for modification to the Behchoko Landfill Design. I have read through the proposed changes and they appear to be practical given the issues with ponding water experienced during construction of Cell 1 while still providing the protective clay barrier for future landfill leachate.

Please consider this email as approval to modify the landfill design as proposed provided the proposal is not rejected by the WLWB. Please adhere to Part F, Condition 2 (as built drawings within 90 days of construction) of Water Licence W2014L3-0002. Take care and have a good day.

Sincerely,

Nahum

From: Alex Packman <alex@sunsetprojectservices.ca>
Sent: Tuesday, June 25, 2024 4:47 PM
To: Meaghan MacIntyre-Newell <Meaghan_MacIntyre-Newell@gov.nt.ca>; Nahum Lee <Nahum_Lee@gov.nt.ca>
Subject: Behchoko Landfill

EXTERNAL: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender's name and email address and know the content is safe.

Meaghan,

As we discussed on the phone, BluMetric has made a slight design modification to the Behchoko landfill design. The change is in section 5.2 landfill base preparation where the material has been changed from clay to granular subbase ontop of the existing clay. This will address the challenges the community had with mud and ponding water on the surface of phase one construction.

We discussed this with Anneli, and she indicated that it is up to the water license inspector to accept the change. Please review and get back to me.

We are planning to resume construction with phase two according to the revised design asap.

Alex Packman
867-445-8069