

From: [Anneli Jokela](#)
To: wekwetisao@northwestel.net
Cc: [Brodie Costello](#); [Roberta Judas](#)
Subject: Water Treatment Facility
Date: January-25-19 2:40:29 PM

Good afternoon Memory,

As a follow-up to the [letter](#) that was sent to the Community Government of Wekweètì (CGW) on November 19, 2018, this email is a reminder that as per Part E, Condition 1 of the Water Licence (W2017L3-0001), the CGW must submit design drawings stamped by a Professional Engineer 90 days prior to the start of construction of the new Water Treatment facility. Also, as per Part E, Condition 3, the CGW must submit as-built drawings of the structures by Professional Engineer within 90 days of completion of the facility.

Should you require additional information or have any concerns don't hesitate to contact Board staff.

Masi,

Anneli Jokela, PhD

Regulatory Manager

Wek'èezhìi Land and Water Board

#1-4905 48th St. | Yellowknife, NT | X1A 3S3

ph 867.765.4588 | fax 867.765.4593

✉ ajokela@wlwb.ca | www.wlwb.ca



All correspondence to the Board, including emails, letters, faxes and attachments are public documents and may be posted to the public registry.