

Jessica Pacunayen

From: Crystal Sabel <csabel@dillon.ca>
Sent: August 13, 2018 13:37
To: Jessica Pacunayen
Subject: Re: Community Government of Gameti - Water Licence Renewal (W2008L3-0003)
Attachments: image001.jpg

Jessica,

In review of the letter from the Wek'eezhii Land and Water Board (July 20, 2017) with the decision of July 12, 2017, I would note following:

WLWB Request - July 20, 2017	Current Submission - August 1 st , 2018
Solid Waste Facility	
<u>Request:</u> Submit Version 2.0 of the Solid Waste Facility Operation and Maintenance Plan with revision and to reflect details of the new facility within 6 months of completion (first day of use)	---
1. As-built drawings of the solid-waste facility are required within 90 days	Unavailable at the time of submission.
2. Continue containing and storing hydrocarbon-impacted materials in sealed drums, as per ECCC Guide and noted in Version 2.0 O&M	Now updated in O&M Plan
3. Community Government directed to ensure Version 2.0 of the O&M reflects updates to Sections 2, 3, and 6.	Now updated in O&M Plan
Wastewater Treatment Facility	
<u>Request:</u> Submit Version 2.0 of the Wastewater Treatment O&M Plan with revisions when it conducts an annual review including:	---
1. Update section 3 to reflect SNP signage at the WTP;	Now updated in O&M Plan
2. Update the Sludge Management Plan to include guidelines identified that will be used to evaluate sludge quality and suitability for cover material; and	Existing Sludge Management Plan, prepared by Dillon Consulting in Oct. 2016, will need to be updated as noted. This work falls outside of the scope of the current contract. To be discussed with client.
Submit as-built drawings for the Wastewater Treatment Facility with additional details within 90 days of receiving the Board's decision	Unavailable at time of submission.
Keep the Board informed of the results of the groundwater monitoring program by including an update to Section 10 of future Annual Reports	Section 10 of the Annual Report is listed as: <i>Updates or revisions to approved plans</i> . To date, no additional groundwater monitoring program results have been included.

Kind regards,

Crystal

On Tue, Aug 7, 2018 at 2:13 PM Jessica Pacunayen <jpacunayen@wlwb.ca> wrote:

Hi Crystal,

Following up on my last email, please also confirm whether the updated O&M Plans have been updated to also reflect the previous directions made by the Board under W2008L3-0003 (e.g., [W2008L3-0003 – Gameti – O&M Plans – Version 1.1 – Directive and Reasons for Decision – Jul 20 17](#)).

Thanks,

Jessica